



CITY OF LODI

COUNCIL COMMUNICATION

AGENDA TITLE: Specifications and Advertisement for Bids
for Construction of Berms (EUD 92-3)

MEETING DATE: March 18, 1992

PREPARED BY: Electric Utility Director

RECOMMENDED ACTION: That the City Council approve the specifications and authorize advertisement for bids for construction of oil containment berms.

BACKGROUND INFORMATION: The oil containment structures will be installed at Henning Substation around oil-filled electrical equipment to confine an oil spill or leak. Recent Environmental Protection Agency regulations require that equipment storing oil in volumes, as in this case, be equipped with a containment system that will prevent an oil spill or leak to extend beyond the immediate area of the equipment and not migrate into the soil, the water table or the site drainage system.

The bid opening date has been set for Tuesday, April 21, 1992

FUNDING: The estimated cost of this improvement, \$15,500, is included in the Department's 1991-92 fiscal year budget.


Henry J. Rice
Electric Utility Director

Prepared by: Hans Hansen, Assist. Electric Utility Director

c: Electrical Engineer
Purchasing Officer

APPROVED


THOMAS A. PETERSON
City Manager